

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2022/ 12/616

Dated: 07/06/2022

FIRE SAFETY CERTIFICATE

Certified that the Oscar Public School located at Kaushik Enclave, Swaroop Nagar Road, Delhi-110086 comprised of 03 block (02 blocks- Ground plus One upper floor & 01 block- Ground floor only) owned/ occupied by Oscar Public School was issued Fire Safety Certificated by this department vide letter No.F6/DFS/MS/2019/1255 dated 12.06.2019 The premises was re-inspected by the officer concerned of this department on 21.05.2022 in presence of Sh. Anil Kumar (Caretaker) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational" with effect from 07/06/2022 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 07/06/2022 at New Delhi by

(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Oscar Public School located at Kaushik Enclave, Swaroop Nagar Road, Delhi-110086.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
5. This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**OSCAR PUBLIC SCHOOL**  
(A UNIT OF STAR Edu. & Social Welfare Society)

Manager