



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/849

Dated: 03/07/2025

FIRE SAFETY CERTIFICATE

Certified that the Oscar Public School located at Kaushik Enclave, Swaroop Nagar Road, Burari, Delhi-110084 comprised of 03 blocks, 02 blocks comprised of ground plus first floor & 01 block comprised of ground floor only owned/ occupied by Oscar Public School was issued Fire Safety Certificated by this department vide letter No. F6/DFS/MS/School/2022/W2/616 dated 07/06/2022 The premises was re-inspected by the officer concerned of this department on 26/06/2025 in presence of Sh. Gopal Dutt (Care Taker) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School)" with effect from ...03/07/2025... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...03/07/2025... at New Delhi by.

(Signature)
Director

Ph:-011-23414000

Copy to :-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.
2. The Manager, Oscar Public School located at Kaushik Enclave, Swaroop Nagar Road, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

HOS/ACADEMIC DIRECTOR
OSCAR PUBLIC SCHOOL
(A Unit of Star Educational &
Social Welfare Society (Regd.)
Kaushik Enclave, Burari, Delhi

True Copy